

November 29, 2010

ADDENDUM 03
TOWN OF COULEE CITY – REDUCTION OF INFLOW AND INFILTRATION TO
WASTEWATER SYSTEM-SUMP PUMP CONNECTIONS

ITEM 1 –
Ice Cover on Lagoons

The recent cold weather has frozen the surface of the lagoons.

The Specifications and Addendum 01 discuss the need to install level loggers into lagoons three and four as soon as possible this winter. The recent cold weather has frozen the surface of these two lagoons. Contractors should consider installing at least HDPE straps (sleeves) to the surface of the water level (ice) this winter and then install remaining pipe and instrumentation in the spring after the lagoons thaw.